



THE SUNSET CAPITAL OF FLORIDA
155 Corey Avenue
St. Pete Beach, FL 33706-1839
www.stpetebeach.org

Addendum 2

Lift Station 13 Rehabilitation

Issued September 19, 2018

Note that this Addendum does not change the bid due date and time as stated in the above referenced RFB. Sealed bids still must be received by 10:00 AM on September 21, 2018 in the Office of the City Clerk, 155 Corey Avenue, St. Pete Beach Florida at which time they will be publicly opened and read. All bidders are invited to attend this bid opening, which will be held immediately following the closing time specified. Bids received after the deadline will not be accepted.

Q: I would like to submit three different materials for consideration to be approved as an equal for the wet well rehabilitation on the Lift Station No. 13 Rehabilitation project bidding on 9/21/18. I attached the Technical Data Sheets. There are two calcium aluminates, and the other is a geopolymer. A brief summary of the geopolymer is below. We have done thousands of VF of this in Florida and all around the country.

A: Only 100% pure fused calcium aluminate cement liners will be allowable. It should be noted that these liners shall have a minimum thickness of 1 inch.

Acknowledge receipt of this addendum by initialing and including this page with the submittal.

Initial _____