



ST. PETE BEACH FIRE RESCUE

BUSINESS TAX LICENSE CHECKLIST *

On behalf of St. Pete Beach Fire Rescue, we would like to welcome you to our City and also welcome your business to our community. The following guidelines are minimum requirements in order to assist you in launching your business in an efficient manner:

- Six inch in height address number shall be provided at front entrance and outside of rear exit door (when applicable). Identification shall contrast with their background.
- Minimum size of a 2A10BC fire extinguisher shall be provided on premise. Fire extinguisher shall be inspected and tagged by a licensed fire extinguisher company and be placed on wall near an exit in an accessible and visible location between two and four feet from the floor. Adequate number of fire extinguisher(s) shall be provided on premise.
- Proper tenant separation shall be provided between occupancies. See NFPA 101, Life Safety Code 2015 edition, Table 6.1.14.4.1
- Exit signs shall be fully illuminated and operable when tested.
- Emergency illumination lights shall be operable.
- If building is provided with a Fire Sprinkler and or a Fire Alarm System, system shall have a current inspection and tag by a licensed fire protection company. Report shall be provided at site.
- No extension cord usage in commercial settings. Surge protectors shall be provided and directly plugged into the outlet.
- Exit door shall have proper hardware.
- Electrical panel directory shall reflect current electrical set up.
- Any ceiling or wall penetrations shall be sealed with fire rated caulk. Foam is not permitted since not a rated material.
- Business shall be set up with furnishings, equipment and all trade fixtures to be used when scheduling the appointment for this inspection.

* This checklist is basic life safety code requirements. Further occupancy requirements per National Fire Protection Association (NFPA), Florida Fire Prevention Code (FFPC) and Life Safety Code 101 (LSC) 2015 edition, shall apply to occupancy upon inspection.

For further information, please contact 727-363-9207.

Kelly Intzes
Fire Marshal